



**K.K.OZA**  
B.E.(Elect.)  
Superintending Engineer (Elect.)  
R & B Department,Gandhinagar  
TO

**VOLTA GREEN ENERGY PRIVATE LIMITED**  
PLOT NO.:148 & 143, AATMIYA-2,  
INDUSTRIAL PARK, On NH-8,  
VILL. MANGLEJ, (POR) VADODARA

Sub:- Request for Approval in S.O.R. for the Year 2026-2027  
Ref:- (a)your company letter dtd:-3/8/2025  
(b)letter from Ex. Engr. Surat/dated:-1/9/2025

No PA /Approval/ 3673 /of 2025  
Superintending Engineer (Electrical)  
R & B Department  
Nirman Bhavan,3rd Floor, Sector No. 10/A,  
3rd Floor, Sector No. 10/A,  
Gandhinagar - 382 010  
Date :-10/9 /2025  
Tele No. :- 079-23253514  
Fax No. :- 079-23254176

After reviewing your company details brought with the S.O.R.-Review Committee , your request for listing the "VOLTA GREEN ENERGY PRIVATE LIMITED " under brand name "VOLTA TRANSFORMERS " in ensuing S.O.R. has been considered in which items / products model which is confirming to our standard & specification befitting on merits were brought on the list of S.O.R. for the the financial year 2026-2027 valid upto 31/3/2027 for use in various Government works executed by Electrical wing of R.&B. Department, Gujarat State

SR	DESCRIPTION	CATEGORY
1	OUTDOOR/INDOOR OIL IMMERSSED NATURALLY ONAN COOLED, DOUBLE WOUND 11 KV/433 V STEP DOWN TRANSFORMER COMPLYING WITH I.S. 2026:2011 & I.S. 1180:PART1:2014, ----- UPTO 66 KV CLASS RANGE ----- UPTO 25 MVA	CAT-III
2	OUTDOOR/INDOOR DRY TYPE(VPI/CRT TYPE) DOUBLE WOUND TRANSFORMERS COMPLYING WITH I.S. 11171 & I.S. 2026:2011 ----- UPTO 33KV CLASS RANGE ----- UPTO 4 MVA	APPROVED
3	OUTDOOR TYPE (CSS)COMPACT SUBSTATION (CSS WITH I NTEGRATED TRANSFORMER + RMU + LT PANEL) & CONFIRMING TO IEC-62227 VPI DRY & OIL IMMERSSED TRANSFORMER -----UPTO 33 KV CLASS RANGE -----UPTO 3500 KVA	APPROVED
4	AUXILIARY TRANSFORMERS CONFIRMING TO IS 1180, IS-2026 & IS 11171 -----UPTO 200 KVA, 33KV CLASS RANGE	APPROVED

The above renewal shall hold good till the product confirms IS /BS /ISI mark and our sor specifications. In case there is any change in Design / Size / Shape of the product, this office should be informed to the same immediately. Failure may lead to cancellation of this inclusion.  
Kindly arrange to send a set of literature of the products to this office as well as to the Office of the Executive Engineers of all Divisions shown below. Please send the Price-Lists to this office periodically as and when the rates are revised.The Department reserves the rights to withdraw the inclusion at any point of time without assigning any reasons thereof.

**K.K.OZA**  
Superintending Engineer (Electrical)  
R & B Department, Gandhinagar